

<b>Clarification of Technical Queries of vendor(S) for the supply of 500 KVA Generator</b>	
<b>Section No</b>	<b>Updated/ revised Specification</b>
No.07	A four pole circuit breaker may be replaced as three pole circuit breaker, wherein the remaining specification will remain same as mentioned in the tender documents.
No.08	A minimum capacity of the fuel tank may be replaced as 8 hours instead of 15 to 18 hours, furthermore additional tank for 8 hours of same specification, quality are also required including all accessories i.e Stand valves and connection pipe etc., wherein the remaining specification will remain same as mentioned in the tender documents.
10 (f)	240mm square 4 core or single core (copper) quoted separately, wherein the remaining specification will remain same as mentioned in the tender documents.